FINAL CERTIFICATE OF ANALYSIS

270208-0 COA N°:

11/07/2017 COA Date: Page 1/1

Customer: SA Farm Assured Meat Group cc

ROB 4927 Order N°:

Client Reference N°:

CT 17-027582 Project N°:



Analysed By Swift Silliker (Pty) Ltd t/a Mérieux NutriSciences

7 Warrington Road Claremont 7708 Western Province

Phone: +27 21 683 8436 Fax: +27 21 683 8420

Received from SA Farm Assured Meat Group cc

P.O. Box 895 Robertson 6760



SA Farm Assured Meat Group cc Jaco du Plessis P.O. Box 895 Robertson 6760

SAMPLE DESCRIPTION

Lab Sample Ref #: CT 17-027582-001

Category Detail: Water

Product Description: Water - Middelburg

Sample N°: 1 723 650 Sample Condition: SEALED Test Date: 05/07/2017 Date received: 05/07/2017

ANALYTICAL RESULTS

Tests	Analysis Start Date	Results	Units	Limits [Target value]
☑ Coliforms		No Growth	cfu/100ml	Result <= 10
METHOD: SWJM 48	05/07/2017			
✓ Escherichia coli		No Growth	cfu/100ml	Not Detected /100ml
METHOD: SWJM 45	05/07/2017			
☑ TMA		860	cfu/ml	Result <= 1000
METHOD: SWJM 35	05/07/2017			

Limits as per SANS 241-1:2015 (EDITION 2)

Results validated on 11/07/2017

Leelain Kordom **Technical Signatory**

Accredited analysis TMA = Total Microbial Activity / Total Viable Plate Count.

* Non Accredited analysis

NC Non Conformance

No growth = Not detected / less than the lower detection limit of the test method, for the specified sample type / volume of sample tested.

 $Tests\ marked\ with\ a\ ^{\star}\ in\ this\ report\ are\ not\ included\ in\ the\ SANAS\ Schedule\ of\ Accreditation\ for\ this\ laboratory\ T0050.$

The test report relates only to specific item submitted for testing. It furnishes or implies no guarantee whatsoever, in respect of a similar item that has not been tested.

Opinions and interpretations expressed in this report, are not included in the SANAS Schedule of Accreditation for this laboratory T0050.

The test report shall not be reproduced except in full without written approval of Swift Silliker (Pty) Ltd t/a Mérieux NutriSciences.